



To

The Principal,
Maharaja Aggarsein Public School,
Jalbera Road Saunda,
Ambala City.

No. 2079 Dated: 04/06/24

Subject:

Request for issue of Building Safety Certificate.

Reference:

Your office Letter No. MAPS / II / 812 dated 13.05.2024 addressed to SDE P-7.

The school building i.e. Maharaja Aggarsein Public School, Vill. Saunda, Jalbera Road, Ambala City (Haryana) was visually inspected by the SDE P-7 alongwith JE incharge. The school building is inspected and visually it found safe for running classes. Hence, the school building safety certificate for year 2024 – 2025 may be issued with following conditions: -

1. Building of this school should be repaired every year.
2. Water should not be allowed to stagnate around and on the roof of the Building.
3. If building is found cracked from anywhere, the same should be got vacated immediately and same should be got repaired immediately.
4. Institution authorities will be responsible for safety of building from every angle and Fire-Fighting equipment's should be in functional condition.
5. If the building of the school is to be extended, the same should be approved from reputed Structural Engineer.
6. Proof Checked structural drawings of the building should be sent to this office for record within 1 month from the issuing of NOC.
7. Institution shall also ensure safety precautions from false ceiling, vitrified used in dado.
8. NOC will be treated as cancelled by this office if the School violates any of the above points.

DA/NIL

Executive Engineer,
Provincial Division No.1,
PWD B&R Br; Ambala Cantt.

Endst. No.

Dated:-

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No. 7, PWD B&R Br; Ambala Cantt for information w.r.t. this office No.735 dated 30.05.2024.

DA/ NIL

Executive Engineer,
Provincial Division No.1,
PWD B&R Br; Ambala Cantt.