

Test Report

Lab. ID. No. : AMB /01685/5/2024/484


Memo No : 1210

Report Issue Date: 22/05/2024

RESULTS						
S. No.	Parameter	Method Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Colour	APHA2120 B	<5	5 HU	15 HU	HU
2	Iron as Fe	APHA 3500 Fe B	0.03	1.0	No Relaxation	Mg/l
3	Sulphate (as SO ₄)	APHA 4500 So ₄	29	200	400	Mg/l

- I. The results given above are related to the sample as received and tested in PHED Lab, Ambala Cantt. Reliability of sample lies with the sender/collector.
- II. The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- III. The test report can't be used for any publicity or any legal purpose.
- IV. The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report.
- V. Sample has not been collected by this lab

Sample analyzed by: Vikram (Water Analyst)


(Arpana Choudhary)
Authorized Signatory/Chemist
PHED Water Testing Laboratory,
Ambala Cantt.